

Government of the People's Republic of Bangladesh
Bangladesh Bridge Authority
Setu Bhaban, New Airport Road
Banani, Dhaka-1212.
www.bba.gov.bd

Memo No.: 50.01.0000.114.31.001.10- 31

Date: 23.01.2022

Subject: Minutes of the Pre-bid Meeting regarding "Supply, Installation, Testing, Commissioning & Maintenance of CCTV cameras & accessories for upgrading the surveillance system of the Head Office, Bangladesh Bridge Authority (BBA), Setu Bhaban, Dhaka." held on 19th January, 2022.

A Pre-Tender Meeting regarding "Supply, Installation, Testing, Commissioning & Maintenance of CCTV cameras & accessories for upgrading the surveillance system of the Head Office, Bangladesh Bridge Authority (BBA), Setu Bhaban, Dhaka." held on 19th January, 2022 at 11.00 am in the office Room of the Director (Administration), BBA, Dhaka. The meeting was presided over by the Director (Administration), BBA.


02. The Director (Administration), BBA welcomed the participants, briefly described the tender document and opened the floor for discussion. Questions regarding the project & documents were raised by the representatives of the tenderers and subsequently the Director (Administration), BBA answered the same. After detailed discussions the following clarification/modification were made for the Tenderer:

Sl No:	Tender Document Reference	Questions / Queries /Request from the Participants	Answers / Comments from BBA
1.	<u>Schedule of Requirement</u> , Section:6 of Tender Document & page No. 65 Item No. 1	The representative from Digital Automation informed that 73 number of cameras cannot be accommodated in one 64-Channel NVR.	Agreed. Assistant Maintenance Engineer(AME) Informed that We have another 32-Channel NVR where rest of the cameras can be accommodated.
2.	<u>Schedule of Requirement</u> , Section:7 of Tender Document & page No. 79 Item No. 10	The representative from Idyllic Technology asked that Does 55" LED Display means TV or anything else.	Not Agreed. The LED display will be used for CCTV Monitoring on 24/7 basis which will be running on 24/7. It should have the tolerance capacity of running on 24/7.
3..	<u>Schedule of Requirement</u> , Section:7 of Tender Document & page No. 73-75 Item No. 3, 4, 5	The representative from Unique Business System asked that Will Face Recognition feature be included in the Bullet Camera & Dome Camera.	Not Agreed. Face Recognition feature is optional. It is not mandatory feature. We will accept the cameras without face recognition.
4.	<u>Schedule of Requirement</u> , Section:7 of Tender Document & page No. 81 Item No. 12	The representative from Nreach Net Pvt said that Video Wall Decoder will be any kind of.	Not Agreed. Video Wall Decoder must be Compatible with the Cameras and other hardware.
5.	<u>Schedule of Requirement</u> , Section:7 of Tender Document & page No. 85	The representative from SIMEC System Ltd asked that Can Video management Software with Hardware be added as a different Item.	Not Agreed. Item will be Video Management Software Compatible with Hardware. Software is the hardware's(Cameras) inbuilt software. We have server PCs . So no need to install server PCs as a separate item.
6.	<u>Schedule of Requirement</u> , Section:7 of Tender Document & page No. 80 Item No.-11	The representative A.K. Khan Telecom Ltd Technologies asked that Will the ANPR camera only use 24" LED display.	Agreed. Only the ANPR Camera will conneted to the 24" LED display.
7.	<u>Schedule of Requirement</u> , Section:7 of Tender Document & page No. 77 Item No.-6	The representative from Digital Automation informed that 08(Eight) SATA hard-drives is used for 64 channel NVR and why did BBA tender for 12(twelve) SATA Hard-drives.	Agreed. We have already 01(one) existing 32-channel NVR and we will set up new 64-channel NVR. So we need Total 12(Twelve) SATA Hard-drives.
8.	<u>Schedule of Requirement</u> , Section:7 of Tender Document & page No. 85	The representative from SIMEC System Ltd wanted to know about the training.	The Director (Admin) of BBA instructed that the cost of training will be same for all the participants. BDT. 50,000 is included as Training cost in the tender.

[Signature]

Sl No:	Tender Document Reference	Questions / Queries /Request from the Participants	Answers / Comments from BBA
9.	<u>Schedule of Requirement</u> , Section:2 of Tender Document & page No. 25	The representative from Nreach Net Pvt wanted to be clarified in details about The minimum supply or production capacity of Goods is BDT 60 Lac.	It has been clarified in the meeting that it was fixed in accordance with the Public Procurement Rules.

03. The chairman thanked all the participants for attending the meeting, wished them for preparing and submitting a good proposal and declared the meeting closed.


(Md. Rupam Anwar) 23/1/2022
Director (Administration)
Ph: 55040310
Email: dir-admn@bba.gov.bd